



Testing according to DIN EN 14041

Client:	HUIDONG WEIKANG RUBBER AND PLASTIC PRODUCTS CO., LTD, Sanzhou Industrial Zone, Huangbu Town, Huidong County, Huizhou City, Guangdong Province, P.R. CHINA		
Product:	PVC flooring, B75		
Order No.:	3056382A		
Dimension:	1209 mm x 145 mm x 4.0 mm (L x W x T)		
Colour:	Yellow; wood pattern		
Surface treatment:	UV lacquer		
Batch no.:	no data		
Date of production:	no data		
Samples received on:	August 07, 2012		
Packaging:	Aluminium foil and cardboard packaging		
Date of order:	July 25, 2012		
Examination:	The examination was carried-out in compliance with the standard DIN EN 14041: Resilient, textile and laminate floor coverings - Essential characteristics.		
Summarized evaluation			
Requirements exclusively regarding the tested parameters			<input checked="" type="checkbox"/> met <input type="checkbox"/> not met

No.	Test	Requirements	Test result	Comment
Test chamber examinations				
1.	Formaldehyde emission	≤ 0.124 mg/m ³ , Class E1	< 0.01 mg/m ³	Requirement met
Material examinations				
2.	Pentachlorophenol (PCP)	≤ 5 ppm (mg/kg)	< 0.5 ppm	Requirement met

Nuremberg, August 14, 2012

TÜV Rheinland LGA Products GmbH
Business Stream Products
LFGB / Consumer Products
Emission Testing

i. A. Konrad Hübschmann
Dipl.-Ing. (FH)

person in charge

i. A. Dr. Bernd Maciej
Chemist

Except when otherwise approved/licensed this test report may only be published and used in unabbreviated original phrasing and form. The test report contains the result of one single examination of the individual test sample and does not represent any universally valid evaluation of the qualities of all products from serial production.

T:\Softlines\LFGB_Konsumgueter\2012\Aufträge Nürnberg\Emissionsprüfung\KUNDEN\TÜV_Shanghai\Berichte\3056382A.doc // Page 1 of 2

TÜV Rheinland LGA Products GmbH • Emission Testing
Tillystraße 2 • 90431 Nürnberg, Germany
Tel. +49 (0) 911 655-5609 • Fax +49 (0) 911 655-5603
E-Mail: bernd.maciej@de.tuv.com • http://www.tuv.com/safety

Company register Nuremberg HRB 26013
Managing Directors:
Dipl.-Ing. Jörg Mähler,
Spokesman Dipl.-Kfm. Dr. Jörg Schlösser
Ust-IdNr. / VAT ID No. DE811835490



Parameter	Test Methods
Test chamber examination:	
Emission of formaldehyde	Test chamber method based on DIN EN 717-1
Material examination:	
Pentachlorophenol (PCP)	Alkaline extraction, derivatisation, GC-MS.

No.	Designation	Picture
1	PVC flooring, B75	